

# MILFORD MUNICIPAL UTILITIES

## 2023 WATER QUALITY REPORT

This report contains important information regarding the water quality in our water system.

The source of our water is surface water. **Our water quality testing shows the following results:**

CONTAMINANT	MCL (MCLG)	COMPLIANCE		DATE	VIOLATION	SOURCE
		Type	Value & (Range)		Yes/No	
Lead (ppb)	AL=15 (0)	90th	2 (ND - 3)	2023	No	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	AL=1.3 (1.3)	90th	0.2 (0.01 - 0.43)	2023	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Total Trihalomethanes (ppb) (TTHM)	80 (N/A)	LRAA	40 (32 - 47)	2023	No	By-products of drinking water chlorination
Total Haloacetic Acids (ppb) (HAA5)	60 (N/A)	LRAA	19 (17 - 23)	2023	No	By-products of drinking water disinfection
<b>DISTRIBUTION SYSTEM</b>						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	1.7 (1.17 - 2.20)	2023	No	Water additive used to control microbes
<b>TREATMENT PLANT</b>						
Fluoride (ppm)	4 (4)	SGL	0.87 (0.37 - 0.87)	2023	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	15	10/5/2023	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	0.12	7/12/2023	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Barium (ppm)	2 (2)	SGL	0.06	4/11/2023	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Arsenic (ppb)	10 (0)	SGL	1	4/11/2023	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production wastes
Dalapon (ppb)	200 (200)	SGL	0.80	7/12/2023	No	Runoff from herbicide used on rights of way
Turbidity (NTU)	N/A (N/A)	TT	Single High 0.089 100% <0.3	2023	No	Soil runoff

**NOTE** - Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

**OTHER INFORMATION** - Turbidity is an indicator of treatment filter performance and is regulated as a treatment technique.

## DEFINITIONS

---

**Maximum Contaminant Level (MCL)**-The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)**-The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**ppb**-Parts per billion

**ppm**-Parts per million

**N/A**-Not applicable

**ND**-Not detected

**RAA**-Running Annual Average

**LRAA**-Locational Running Annual Average

**SGL**-Single Sample Result

**NTU**-Nephelometric Turbidity Units

**Treatment Technique (TT)**-A required process intended to reduce the level of a contaminant in drinking water.

**Action Level (AL)**-The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Residual Disinfectant Level Goal (MRDLG)**-The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Maximum Residual Disinfectant Level (MRDL)**-The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**GENERAL INFORMATION** - Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Milford Municipal Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**SOURCE WATER ASSESSMENT INFORMATION** - This water supply obtains water from one or more surface waters. Surface water sources are susceptible to sources of contamination within the drainage basin.

<u>Surface Water Name</u>	<u>Susceptibility</u>
West Lake Okoboji	High

**CONTACT INFORMATION** - Milford Utilities will not be mailing copies of the Consumer Confidence Report to its customers. Copies are available at the Milford Municipal Utilities office located at 806 N Avenue, Suite III. For questions regarding this information or how you can get involved in decisions regarding the water system, or if you would like a report to be mailed to you, please contact Milford Municipal Utilities at 712-338-2401. You can view the water quality report at <https://milfordiautilities.com/2023CCR>